



# CERTIFICATE OF PRODUCT CERTIFICATION

## CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

**CERTIFICATE NO.:** CQC22701343688

**Valid from:** Jun.06,2022

**Valid until:** Jun.05,2027

<b>NAME AND REGISTERED ADDRESS OF THE APPLICANT</b>	SHENZHEN CONSNANT TECHNOLOGY CO.,LTD BUILDING NO.B6, JUNFENG INDUSTRIAL PARK,YONGHE ROAD,FUYONG TOWN,BAO`AN DISTRICT,SHENZHEN CITY,GUANGDONG
<b>BRAND NAME</b>	CONSNANT
<b>NAME AND REGISTERED ADDRESS OF THE MANUFACTURER</b>	SHENZHEN CONSNANT TECHNOLOGY CO.,LTD BUILDING NO.B6, JUNFENG INDUSTRIAL PARK,YONGHE ROAD,FUYONG TOWN,BAO`AN DISTRICT,SHENZHEN CITY,GUANGDONG
<b>NAME AND LOCATION OF THE FACTORY</b>	SHENZHEN CONSNANT TECHNOLOGY CO.,LTD BUILDING NO.B6, JUNFENG INDUSTRIAL PARK,YONGHE ROAD,FUYONG TOWN,BAO`AN DISTRICT,SHENZHEN CITY,GUANGDONG
<b>PRODUCT NAME,</b>	UPS
<b>MODEL AND SPECIFICATION</b>	See Appendix
<b>THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS</b>	CQC3108-2011
<b>TYPE OF CERTIFICATION SCHEMES</b>	Product Testing + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of CQC31-461234-2009.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦

CHINA QUALITY CERTIFICATION CENTRE



# CERTIFICATE OF PRODUCT CERTIFICATION

## CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO. : CQC22701343688

page 1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

Model	Input	Output	Rated capacity	Size ( mm )
CNG330 100kVA	3Φ+N+PE 380Vac, 170A,50/60Hz,PF>0.99	3Φ+N+PE 380Vac, 152A 50/60Hz	100kVA/80kW power factor 0.8	800*800*1900
CNG330 120kVA	3Φ+N+PE 380Vac, 204A,50/60Hz,PF>0.99	3Φ+N+PE 380Vac, 182A 50/60Hz	120kVA/96kW power factor 0.8	800*800*1900
CNG330 160kVA	3Φ+N+PE 380Vac, 272A,50/60Hz,PF>0.99	3Φ+N+PE 380Vac, 243A 50/60Hz	160kVA/128kW power factor 0.8	800*850*1900
CNG330 200kVA	3Φ+N+PE 380Vac, 339A,50/60Hz,PF>0.99	3Φ+N+PE 380Vac, 304A 50/60Hz	200kVA/160kW power factor 0.8	800*850*1900
CNG330 250kVA	3Φ+N+PE 380Vac, 424A,50/60Hz,PF>0.99	3Φ+N+PE 380Vac, 380A 50/60Hz	250kVA/200kW power factor 0.8	1200*850*1900
CNG330 300kVA	3Φ+N+PE 380Vac, 509A,50/60Hz,PF>0.99	3Φ+N+PE 380Vac, 456A 50/60Hz	300kVA/240kW power factor 0.8	1400*1100*2000
CNG330 400kVA	3Φ+N+PE 380Vac, 679A,50/60Hz,PF>0.99	3Φ+N+PE 380Vac, 608A 50/60Hz	400kVA/320kW power factor 0.8	1400*1100*2000



CHINA QUALITY CERTIFICATION CENTRE